



GIG
CYMRU
NHS
WALES

Bwrdd Iechyd Prifysgol
Cwm Taf Morgannwg
University Health Board



Freedom of Information Request: Our Reference CTMUHB_479_24

You asked:

Please can you provide the data for the amount of water used, and the cost, for all of the major hospitals within the Cwm Taf Health Board, within the past TWO years.

Our response:

The amount of water used (m³), and the cost, for all of the major hospitals within the Cwm Taf Morgannwg University Health Board, over the past two financial years is provided in the table below.

Please note that the consumption (m³) is for water only. The water costs also include the daily service charge for water. The costs do not include any sewerage disposal costs, nor sewerage disposal daily service costs. The unit costs for water change on 1st April annually.

Hospital Name	FY 2022 - 2023 Water Only		FY 2023 - 2024 Water Only	
	Consumption (m3)	Cost*	Consumption (m3)	Cost*
Glanrhyd Hospital	21,053	£30,810	30,563	£48,878
Prince Charles Hospital	61,446	£83,211	64,104	£94,405
Princess of Wales Hospital	108,657	£131,229	111,841	£146,956
Royal Glamorgan Hospital	66,280	£89,415	75,168	£106,466
Ysbyty Cwm Cynon	18,293	£26,791	18,322	£29,434
Ysbyty Cwm Rhondda	11,572	£17,573	11,772	£19,591
Ysbyty George Thomas	5,398	£8,626	8,736	£14,763

Water Only Totals

292,699 £387,654

320,506 £460,492

*Inc Daily Service Charges.

Annually on 1st April, Dwr Cymru Welsh Water change their daily service charge unit rates & water unit rates.

The Princess of Wales Hospital is heated by steam hence the increased water use & cost compared to Prince Charles Hospital & Royal Glamorgan Hospital.