

Freedom of Information Request: Our Reference CTMUHB_116_26

You asked:

Would it be possible to obtain the following information please.

Water and heating issues on ward 4 of The Princess of Wales Hospital.

We would like any recorded issues, incidents or repairs between the dates of 22nd Oct 2024 and 24th Nov 2024.

Our response:

Please see the information we hold provided in the table below:

Description	Instructions
Tap running Male shower and female shower rooms	Taps are running not turning off properly in Male shower room and Female shower room ward 4 POWH
Sink In domestic room Legs rusty and loose Ward 4	Sink in Domestic room legs are loose and rusty picked up by infection control audit
Dish Washer Ward 4 POWH	Dish washer not working only producing dirty water into machine
Seal around sink in treatment room needs replacing	Seal around sink in treatment room needs replacing ward 4 pow
Blocked sink Cubicle 4 Ward 4 POWH	Blocked sink Cubicle 4 Ward 4 POWH
Drain in male shower blocked Ward 4 POWH	Drain in Male shower blocked Ward 4 POWH
Blocked sink cubicle 3ward 4 POWH	Blocked sink cubicle 3 Ward 4 POWH
Water brown in staff toilet and blue bay Ward 4	Water running brown in Blue Bay and Staff toilet Ward 4 POWH
radiator heater in yellow bay	radiator heater in yellow bay not working (ward 4 POW)
Ward 4 Cardiology POW	the hot tap in the HMC is not working properly
toilet leaking	when flushing the toilet leaking down the wall in toilet nearest yellow bay
Ward 4, POWH	Blue bay toilet is blocked